



NOTES:

1. EQUIPMENT GROUND WIRE & BARE WIRE SHALL BE SECURELY FASTENED TO THE GROUND LUG INSIDE THE POLE HANDHOLE. ALL BONDING & GROUNDING CONNECTIONS SHALL REMAIN ACCESSIBLE FOR INSPECTION AND MAINTENANCE.
2. IF THE FIXTURE MANUFACTURER HAS MADE PROVISION FOR THE ATTACHMENT OF A GROUND WIRE A GREEN INSULATED WIRE OF THE SAME SIZE SHALL BE RUN FROM THE FIXTURE TO THE GROUND LUG INSIDE THE POLE HANDHOLE. IF THE FIXTURE MANUFACTURER HAS A GROUND LUG A #8 GREEN INSULATED WIRE SHALL BE RUN FROM THE FIXTURE GROUND LUG TO THE POLE GROUND LUG.



PUBLIC WORKS
DEPARTMENT

**TYPICAL LIGHTING
UNDERGROUND SYSTEM**

STD. PLAN - 119

APPROVED:

CZ

DATE

1/26/15